

Nr	Pomieszczenie	Kub. m ³	ilość powietrza nawiew	ilość powietrza wywiew	ilość wymian nawiew	ilość wymian wywiew	Ilość osób	Ilość pow. Na os.	Temperat ura zima	Temperat ura lato	System	Uwaga
PARTER												
2	Hall wejściowy	304	50	400	0,2	1,3	3,0		20	25	NW1	
3	szatnia	25	0	50	0,0	2,0	3,0		20	25	NW1	
4	rejestracja	98	400	0	4,1	0,0			20	25	NW1	
5	pokój śniadań	31	80	80	2,6	2,6	-	-	20	25	NW1	
6	pokój badań	39	100	100	2,6	2,6	-	-	24	25	NW1	
7	pom. tech	12	30	30	2,5	2,5	-	-	20	25	NW1	
10	komunikacja	126	190	150	1,5	1,2	-	-	20	25	NW1	
11	pom tech	7	-	40	-	5,7	-	-	20	25	NW1	TRANSFER POWIETRZA Z POM. NR 10
12	komunikacja poczekalnia	112	280	200	2,5	1,8	9	30	20	25	NW1	
13	wc personelu	10	80	50	8,0	5,0	-	-	24	25	WC	
14	skład porządkowy	4	-	30	-	6,8	-	-	20	25	WC	TRANSFER Z WC PERSONELU
15	pokój psychologa	65	130	130	2,0	2,0	-	-	20	25	NW1	
16	pokój psychologa	64	130	130	2,0	2,0	-	-	20	25	NW1	transfer nawiewu z sali szkoleń
17	sala szkoleń	88	180	160	2,1	1,8	6	30	20	25	NW1	
18	aneks kuchenny	18	-	50	-	2,8			20	25	Wa	
19	pokój badań	46	100	100	2,2	2,2			24	25	NW1	
20	wc pacjentów	11	-	50	-	4,6			24	25	Wc	transfer z komunikacji nr 12
21	magazyn	5	-	30	-	5,9			20	25		